



TEST REPORT

Page 1 of 5

REPORT NUMBER : TURR130177536

APPLICANT NAME ÇET-SAN Pls. Elk. Malz. San. Tic. Ltd.

ADDRESS İkitelli Org. San. Böl. İpkas San. Sit.
Fax : 0212 5494812
Attention : Selahattin Ulaş (info@cet-san.com.tr)

SAMPLE DESCRIPTION : One sample of Grey surface mounted plug box

DATE IN : 06 December, 213 (12:00)

DATE OUT : 24 December, 2013

PRODUCT'S CODE : See Attachement

TEST	Sample
HALOGEN CONTENT	NR

P = MEETS BUYER' S REQUIREMENT / F = DOES NOT MEET BUYER' S REQUIREMENT / NR = NO REQUIREMENT / SC=STILL CONTINUES / X=NOT PERFORMED

The test results relate only to the items tested. The whole and/or the part of this test report shall not be reproduced and shall not be shared with third parties, nor to be used for PR activities without the written permission of INTERTEK Test Hizmetleri A.S.

Bora Şirinbilek
Coordinator

Neslihan Sözer
Chemical Laboratory Manager

Intertek Test Hizmetleri A.S.
Merkez Mahallesi Sanayi Cad. No.23 Altındag Plaza Yenibosna 34197 - ISTANBUL / TURKEY
Phone : +90.212. 496 46 46 Fax: +90.212. 452 80 55
e-mail : intertekcg.turkiye@intertek.com
www.intertek-turkey.com



130177536

KB.0060	Boş 1'li Kombinasyon Kutusu
KB.0060-1	Boş 1'li Kombinasyon Kutusu Delikli
KB.0050	Boş 2'li Kombinasyon Kutusu
KB.0050-1	Boş 2'li Kombinasyon Kutusu Delikli
KB.0070	Boş 4'li Kombinasyon Kutusu
KB.0070-1	Boş 4'li Kombinasyon Kutusu Delikli
KB.0080	Boş 6'li Kombinasyon Kutusu
KB.0080-1	Boş 6'li Kombinasyon Kutusu Delikli

(±) (I) HALOGEN CONTENT

Testing Item	Result (mg/kg)
Fluorine (F) Content	ND
Chlorine (Cl) Content	ND
Bromine (Br) Content	65100
Iodine (I) Content	ND

Remarks : Ppm = Parts Per Million
ND = Not Detected


Test Method :

Testing Item	Testing Method	Reporting Limit
Halogen (F, Cl, Br, I) Content	With reference to BS EN 14582:2007 by Calorimetric Bomb and determined by Ion Chromatography	50 ppm

Remarks : Reporting Limit = Quantitation Limit of Analyte in sample

(±) This test was performed by Intertek Shenzhen

**(‡) (II) MEASUREMENT FLOWCHART :
TEST FOR HALOGEN CONTENT
REFERENCE METHOD : BS EN 14582 : 2007**



(‡) This test was performed by Intertek Shenzhen



END OF TEST REPORT